

Mobrey Vertical magnetic level switches

Data sheet IP107

- Weatherproof
- Flameproof
- · Direct mount
- Chamber mount
- Displacer controls



Operation

The float carries a stainless steel sheathed permanent magnet which rises and falls in the glandless pressure tube with changing liquid level.

A switch mechanism is mounted inside the enclosure adjacent to the pressure tube.

Switching is achieved with the unique Mobrey 'three-magnet' system, giving snap-action 'latch-on' switching.

Vertical movement of the float magnet in the pressure tube simultaneously actuates the secondary and tertiary magnets in the switch mechanism to operate the contacts. This 'three-magnet' system enables the float magnet to pass on and actuate switch mechanisms at other levels. Switch mechanisms already actuated cannot re-set until the return of the primary magnet actuates the magnet system once again.

- Unique 3 magnet latching switch mechanism
- No springs in switch mechanism

Contents

Introd	duction	Page 3
Switc	h Mechanisms	4
1.	Direct mount displacer controls	5-7
2.	Direct mount float switches	8-9
3.	Chamber mounted controls 3.1 Carbon steel chambers	10-11
	3.2 316L stainless steel chambers	12-13
4.	Dimensional and operating level data	14
5.	Technical data and options	15
6.	Applications and users	16







Whether you require a switch for critical area applications or just general purpose control, the extensive range of Mobrey chambers ensures that we will always have a solution to your particular problem.

A choice of carbon steel chambers is available, or for more rigorous applications we supply a series of 316 stainless steel chambers. A variety of tank and process connections are available to make installation simple and economic. This gives you the choice to meet your application in keeping with your budget.

Introduction

Whether you require a switch for critical area applications or just general purpose control, the extensive range of Mobrey chambers ensures that we will always have a solution to your particular problem.

A choice of carbon steel chambers is available, or for more vigorous applications we supply a series of 316 stainless steel chambers. A variety of tank and process connections is available to make installation simple and economic. This gives you the choice to meet your application in keeping with your budget.

Mobrey vertical magnetic level switches for industrial and process control use have been available for over 20 years and have been steadily gaining a reputation for quality and reliability.

Based on the industry standard boiler water level controls these controls employ the same three magnet switch mechanism for snapaction latching switching.

The design of this unique switch mechanism overcomes all the inherent problems of mercury tubes and micro switches. Even under severe vibration conditions there are no springs to cause contact bounce, hover, or even failure. The snap action magnets give positive stable latching time after time after time.

There are two switching functions available: 2 x SPST (SPCO) switching or DPDT (DPCO) switching, and each comes in four variants:-

- General purpose use with silver cadmium oxide contacts for long life
- Low power circuit used with gold plated contacts for use in low current/voltage applications such as I.S. circuits.
- High power circuits giving up to 10A switching capability.
- Hermetically sealed for the ultimate in reliability - sealed for life.

When controls are required to operate in extreme conditions, the unique Mobrey hermetically sealed switch provides dependable life long operation that you can rely on. With all its moving parts and contacts completely enclosed, this genuine

hermetically sealed switch is suitable for use in corrosive atmospheres and low temperature environments.

Features

- Unique switching mechanism
 totally reliable
- No springs in switch mechanism
 positive snap action switching
- Vibration resistant
 - eleminates spurious trips
- Multi-switching models
 - cost effective control
- Genuine hermetically sealed switch option - totally safe and secure
- Material certification to DIN 50049 3.1B
- Materials to ASTM and B.S. Standards

Approvals

Mobrey vertical controls are certified E Exd IIC T6 in accordance with BS5501 Part 5 (en50018).

BASEEFA certificate no. 90C1262


Flameproof models are available constructed in either aluminium alloy to keep weight to a minimum or cast iron for extended usage in arduous environments. Users must comply with installation details given in leaflet IP153.

Intrinsically Safe Use

For use in intrinsically safe circuits, gold plated switch contacts are recommended (see page 4). Users are reminded that it is their responsibility to obtain the necessary system approval and licences for such circuits.

BS5750 : Part 1

Solartron Mobrey Ltd has been assessed and approved by Lloyds



Section through type H4 switch mechanism




Hermetically sealed switch mechanism


Register Quality Assurance Ltd against BS5750: Part 1: 1987 and ISO 9001 - 1987 EN 29001 - 1987 for the design, development and manufacture of electrical, mechanical and ultrasonic level measuring equipment.

Quality Assurance

With over 20 years worldwide experience in the major power, nuclear and petro-chemical industries, Solartron Mobrey is able to accommodate testing, surveying and documentation requirements as specified at the time of order. Inspection by customers or nominated inspection agencies can be arranged.


KDG Mobrey Switch Mechanisms






Note: For DPDT operation, installer must common any one pair of A and B wires in the terminal block for each of the two ends of the switch mechanism.

Switch Enclosures





Type D4, D8: General purpose switch mechanism.

Type X4, X8: High current switch mechanism.

Type P4, P8: Switch mechanism with gold plated contacts for use in low power or intrinsically safe circuits.

Type H4, H8: Hermetically sealed mechanism with all moving parts and contacts enclosed in an inert gas filled stainless steel enclosure. Suitable for use in low temperatures, contaminated atmospheres and intrinsically safe circuits.

Electrical Rating

Туре	Temp	Low	AC	max. va	lues		DC max	c. values	
	wetside	temp	VA	Volts	Amps	Watts	Volts	Res	Ind
	°C	use						amps	amps
D4, D8	400	No	2000	440	5	50	250	5	0.5
X4, X8	250	No	2000	440	10	50	250	10	0.5
P4, P8	400	No	6	250	0.25	3.6	250	0.25	0.1
H4, H8	250	-50℃	2000	440	10	50	250	10	0.5

Each switch mechanism has flying leads which are factory wired to ceramic terminal blocks fixed in the switch enclosure.

Warning

Gold plating on the contacts of P4 and P8 switch mechanisms may be permanently damaged if the mechanisms are used to switch circuits with values greater than those shown above.

Switches must not be used for the direct starting of motors. Contacts should be wired in series with the operating coils of relays, contactor starters or solenoid valves and fused separately.

Weatherprooof IEC144: IP66.

Aluminium alloy based/drawn steel cover.

Type R4N: Fixed switch

Type S4N: 100mm switch adjustment Type L4N: 200mm switch adjustment

Flameproof EExdIICT6 (Weatherproof IP66)

Aluminium alloy base and cover "A" Cast iron base and cover "I"

Type R7A/R71: Fixed switch

Type S7A/S71: 100mm switch adjustment

Conduit entries

Enclosures supplied with four contact switch mechanisms have a single 1" NPT conduit entry.

Enclosures supplied with eight contact switch mechanisms have 2 \times 1" NPT conduit entries.

Users must comply with the approval requirements for connection as detailed in Installation Leaflet IP153.

Tube and Unions: 316 stainless steel throughout. Welded construction with additional swaging technique to ensure maximum integrity. Individually pressure tested to 150 bar (operating pressure will be limited by float or flange specified).

Paint Finish: Black stove paint. Epoxy paint finishes available on request.

1.0 Direct Mount Displacer Cont


Mobrey displacer operated controls are ideal for sump application and other top mounting duties such as low level alarm in deep tanks. Their principle of operation also makes them suitable, in a modified form, for very high pressure or low S.G. applications.


The four most popular displacer arrangements are shown in this schematic diagram, which covers most of the likely applications. However, should you have a different requirement, we would be pleased to quote a model for your particular application.


Principle of Operation


The displacer element, made of either 316 stainless steel or ceramic depending upon duty, is suspended on a stainless steel cable from a spring. The element is always heavier than its equivalent volume of the liquid in which it is to operate, and so will extend the tension spring at all times. In free air, the spring will be extended to a known length, controlled by a mechanical stop to prevent overstressing. Fixed to the spring is the float rod and magnet assembly, free to move up and down as the spring extends or contracts, and outside the pressure tube in the usual manner is the switch mechanism.


As liquid rises to cover the displacer element, a bouyancy force is created equal to the weight of the liquid displaced. This force in effect is seen by the spring as a reduction in weight, causing the spring to











contract, hence moving the magnet upwards inside the pressure tube and actuating the switch mechanism. On a falling liquid level, the displacer element is uncovered and the spring sees an increasing effective weight, causing the spring to extend and move the magnet to re-set the switch mechanism (Fig i and v).

This simple principle can be refined to operate a single switch over a very wide differential by providing the buoyancy force from two elements instead of just one (Fig ii).

Two switch models are available for either two alarm duty with two narrow differentials (Fig iii) or for pump control/alarm duty with appropriate differentials (Fig iv).

In all cases, because the elements are suspended on a cable, switching or control levels can be several metres below the mounting flange, and are fully field adjustable by resetting the elements on the cable.




Displacer Controls: Ordering Information

Code	Disp	lacer op	perated	alarn	n and	pun	пр с	ontrol sw	itches									
)	Direc	t moun	nt: Disp	lacer	contr	rols												
	Code	Mater	rial of ı	mount	ing fl	lange	;											
	С	Carbo	n stee	I. AST	M A1	.05 (For	use +300	°C to -10°0	C)								
	S	315L	. stainle	ess ste	eel. A	STM	A18	32: F316	L (For use	+3	800°C to -5	0°C)						
		Code	Displa	acer fu	unctio	on ar	nd s	pecification	on									
								Material	of		S.G.	Ran	ge	(Opera	ting	Max.	pres.
			Fur	nction	EI	emei	nts	Trim	Spring	3	4 Contact	8 0	ontact	te	mp.	range	20	O°C
		1D	One	switc	h 3:	16 S	S.				0.6 - 1.2	0.7	5 - 1.2	-50	°C to	+300°C	;	
			narro	w dif	f.													
		2D	One	switc	h 3:	16 S	S.	316	Nimoni	ic	0.5 - 1.2	0.7	5 - 1.2	-50	°C to	+300°C		
			wid	e diff.				Stainles	s 90								-	02
		3D		switcl		16 S	.S.	Steel			0.6 - 1.2	0.8	3 - 1.2	-50	°C to	+300°C	b	ar
				de dif	_					-								
		8D		switcl		15 S.	.S.				0.6 - 1.2	0.6	5 - 1.2	-50	°C to	+300°C	7	
			2 nor															
			Code	SWIT	cn er	iclos	ure	Mater	ial of		Material	of	Ç.	vitch	l A	/lax. no	of c	witch
					Duty			Base	Cover		wetted pa		٠.	viich stmen			. or sv nanisn	
						roof		ıminium	Drawn		wetteu pa	1113		djust		IIICCI	iaiiisii	113
			S4N		IP66	1001	l	alloy*	steel				switch	-	int			
			34N		11 00			ıminium	Aluminiur	m	316			noving			2	
			S7A	Flan	mepro	oof		alloy*	alloy	``	stainles	s		placer			_	
			3/A		xdIIC			Cast	Cast		steel			ments				
			S71		· Carro			iron	iron					cable				
			0,1				*	Base mate	rial will b	e c	ı ast iron wh	lenev	er 8 co	ontact	swite	ches ar	e sned	rified
				Code	Nu	mbe			echanisms				<u> </u>					
				1	Sp	ecify	1 fc	or single s	witch mod	dels	s 1D, 2D, 4	1D, 5	D					
				2	Sp	ecify	2 f	or two swi	tch model	s 3	BD, 6D, 8D	, 9D						
					Coc	le 1	уре	of switch	mechanis									
							5	Switch me			ax. wetside			ues		D.C. ma	x. value	s
								du		te	mperature	Volts	Amps	VA	Volts	Res. I	Ind. I	Watts
							•		2 × SPST									
					D4			ral purpos			300℃	440	5	2000	250	5	0.5	50
					P4			oower circ			300°C	250	0.25	6	250	0.25	0.1	3.6
					X4		_	power cir			250°C	440	10	2000	250	10	0.5	50
					H4	H		etically se			250℃	440	10	2000	250	10	0.5	50
					-			ral purpos		-	300℃	440	5	2000	250	5	0.5	50
					D8			ower circ			300°C	250	0.25	2000	250 250	0.25	0.5	3.6
					P8 X8			power cir			250°C	440	10	2000	250	10	0.1	50
					H8		_	etically se			250°C	440	10	2000	250	10	0.5	50
					ПО	-	<i>,</i>	otrouriy oc	Jaroa		2000	110	10	2000	200	10	0.0	
							C	ode Mou	inting arra	ng	ement							
							0	1" [N.P.T. Thre	ead	: 316 stair	iless	steel s	standa	rd	These	are o	ur
							60				NSI B16.5/					stocke	d flar	iges.
							6				NSI B16.5/					Other	_	
							6				NSI B16.5/					sizes a		-
							6				NSI B16.5/					are av	ailable	е
							6				NSI B16.5/					on		
							6		‡ 600 R.F.	A١	NSI B16.5/	BS15	60			reque	st.	
		V 3D	S7A	<u>V</u>	<u>V</u> D4	<u>/ </u>		<u>√</u> 60						Typic	ما معط	lering i	nform	ation
U	C	วบ	3/A		טי	+ /		00						Typica	ai Urd	ering I	HOTTI	auuli

Note: Customers must state operating pressure, temperature and specific gravity, together with function of each switch mechanism when ordering.

Due to component tolerances, dimensions D, DB, E and S given on page 7 are approximate and may vary on each control by up to 10mm. Setting the control to operate at the required level can be achieved on site by adjusting the element up or down on the cable as necessary.


Displacer types and dimensional details



Switch	D4	P4	X4	Н4	D8	P8 X8	Н8
types							
S.G.							
S min	315	335	365	380	275	320	340
Е	90	70	60	55	135	105	90

Single switch wide differential: 2D, 5D

The two displacer elements are positioned at any point on the cable to correspond to the switching levels required. When the liquid level drops to the lower displacer the switch is actuated and starts (or stops) a pump; when the liquid rises to the upper displacer the switch is again actuated to stop (or start) the pump.



2D St. Steel: A = 216 \emptyset = 60.3

Switch	D4	P4	Х4	H4	D8	P8	Х8	Н8
types								
S.G.								
S min								
E min	165	110	95	80	205	200	165	140


S min = Adjustable distance to upper switching level.

E min = Differential

D = Minimum dead band

Two switch 2 narrow differentials: 8D, 9D

The displacers are positioned to form two elements of similar lengths, such that two alarm points may be given. This arrangement is typical of sump application.




8D St. Steel: A = 216 \emptyset = 60.3

OD 31. 3	icci. A			ω – ω	,.J			
Switch	D4	P4	Х4	H4	D8	P8)	K 8 H	8
types								
S.G.	0.6	0.8	1.0	1.2	0.8	1.0	1.	2
S min	390	385	375	365	355	350	34	-5
E min	90	70	60	55	135	105	90	C
Dead band	200	230	255	310	165	215	25	0

Two switch 2 wide differentials: 3D, 6D


A pump is controlled between the middle and the lower pump displacers positioned on the cable at the required levels. Should the level rise to the upper displacer this actuates the upper alarm switch which remains actuated until the level drops to the middle displacer.



Alternatively, the upper switch could control a second pump.

3D St. Steel: A = 152 B = 304 \emptyset = 60.3

JD JL. J	LEEI. /	л — т.	7Z D -	- 504	$\omega - 00$			
Switch	D4	P4	Х4	H4	D8	P8	Х8	Н8
types								
S.G.	0.6	0.8	1.0	1.2	0.8	1	.0	1.2
S min	390	385	375	365	355	3	50	345
E min	135	110	95	80	200	14	45	140
Dead band	220	255	285	310	165	2	15	250




2.0 Direct Mounting Float Switches: Ordering Information


Code	t mount		switche nounting											
						20:21 10:2								
С				-		00°C to -10°C		100	١٠٠٠)					
S	Code		s steel		1182: F31	L6L (for use +	400°C to	-100)°(C)					
	Code										1			
			mum			ting (bar)	Floa	-	Matc	_			tchin	_
		S.		20°			diame	ter	enclos	sures		mounti		
	1F	0.8	80	34.			67					3" NB	and I	arger
	2F		75	102			90		All mo	odels				
	3F		65	51.	_ '		88					4" NB	minii	mum
	4F	0.	54	19.	6 12.	.1 6.5	88							
		Code	Switch	Enclos	ure			'			•			
					Materia	al Materia	l Ma	terial o	of	Switch	h N	/lax. no.	of sv	vitches
			Duty		of base	e of cove	r wett	ed pa	rts a	djustm	ent 4	4 Conta	ct 8	Conta
		R4N	Weath	erproof	Aluminiu	ım Drawn		-		None		1		1
		S4N	IP66		alloy*	steel			-	100mr	m	4		2
		L4N						316		200mr	m	6		3
		R7A	Flamer	proof	Aluminiu	um Aluminiu	m st	ainless	s –	None	;	1		1
		S7A	EExdII(CT6	alloy*	alloy		steel		100mr	m	4		2
		R71			Cast	Cast				None		1		1
		S71			iron	iron				100mr	m	4		2
	1					<u> </u>							ecifie	4
1					*Base ma	nterial will be o	cast iron	whene	ever 8	contact	SWITC	cnes sp	CCITIC	J.
			Code			terial will be o		whene	ever 8	contact	SWITC	cnes sp	CCITIC	J.
			Code	Numb	er of switc	ch mechanism	S					•		J
				Numb	er of switc		S							u.
				Numb	er of switc	ch mechanism	s allowab							J.
				Number As req	er of switch	ch mechanism e max. number	s allowab	le in s		enclosu	ure da		re	
				Number As req	er of switch Type of s Switch	ch mechanism e max. number switch mecha	s allowab	le in s	max va	enclosı lues	ure da	ata abov	e value	es
				Number As req	r of switce uired: see Type of : Switch	ch mechanism e max. number switch mechan mechanism	s allowab	le in s	max va	enclosı lues	ure da	nta abov	e value	es
				Number As req	r of switce uired: see Type of : Switch	e max. number switch mechan mechanism duty ct: 2 x SPST	allowab nism Max. wetside	AC r	max va	enclosı lues	ure da	nta abov	e value	es
				As req	Type of Switch 4 contact General	e max. number switch mechan mechanism duty ct: 2 x SPST	mism Max. wetside temp. 400°C	AC r Volts	max val Amps 5 0.25	lues VA 2000	Volts 250 250	DC max	value Ind. 0.5 0.1	50 3.6
				As req Code	Type of Switch 4 contact General Low pow	e max. number switch mechan mechanism duty ct: 2 x SPST purpose	mism Max. wetside temp. 400°C	AC r Volts	max val Amps	lues VA 2000	Volts 250 250	DC max Res. I	value	s I Watt
				Numb As req Code	Type of : Switch 4 contact General Low pow High pov	switch mechanism duty ct: 2 x SPST purpose ver circuits	mism Max. wetside temp. 400°C	AC r Volts 440 250 440	max val Amps 5 0.25	lues VA 2000	Volts 250 250 250	DC max Res. I 5 0.25	value Ind. 0.5 0.1	50 3.6
				Numb As req Code D4 P4 X4	Type of Switch 4 contact General Low pow High pow	e max. number switch mechan mechanism duty ct: 2 x SPST purpose ver circuits wer circuits	mism Max. wetside temp. 400°C 400°C 250°C 250°C	AC r Volts 440 250 440 440	max va Amps 5 0.25 10	enclosu lues VA 2000 6 2000 2000	Volts 250 250 250 250	DC max Res. I 5 0.25 10	value Ind. 0.5 0.1 0.5 0.5	50 3.6 50 50
				Number As required D4 P4 X4 H4 D8	Type of Switch 4 contact General Low pow High pow	switch mechanism duty ct: 2 x SPST purpose ver circuits wer circuits cally sealed tact: DPDT	Max. wetside temp. 400°C 250°C 250°C 400°C	AC r Volts 440 250 440 440	max val	enclosu lues VA 2000 6 2000 2000	Volts 250 250 250 250	DC max Res. I 5 0.25 10 10	value Ind. 0.5 0.1 0.5 0.5 0.5	50 3.6 50 50 50
				Numb As req Code D4 P4 X4 H4 D8 P8	Type of Switch 4 contact General Low pow High pov Hermetic 8 contact General Low pow	switch mechanism mechanism duty ct: 2 x SPST purpose ver circuits wer circuits cally sealed tact: DPDT purpose ver circuits	mism Max. wetside temp. 400°C 400°C 250°C 250°C 400°C 400°C	AC r Volts 440 250 440 440 250	max va Amps 5 0.25 10 10 5 0.25	enclosu lues VA 2000 6 2000 2000 6	Volts 250 250 250 250 250 250	DC max Res. I 5 0.25 10 10 5 0.25	value Ind. 0.5 0.1 0.5 0.5 0.5 0.1	50 3.6 50 50 50 3.6
				Numbi As req Code D4 P4 X4 H4 D8 P8 X8	Type of switch 4 contact General Low pow Hermetic 8 cont General Low pow Hermetic	switch mechanism mechanism duty ct: 2 x SPST purpose ver circuits wer circuits cally sealed tact: DPDT purpose ver circuits	Max. wetside temp. 400°C 250°C 400°C 400°C 250°C 250°C 250°C 250°C	AC r Volts 440 250 440 440 250 440	max va	enclosu lues VA 2000 6 2000 2000 6 2000 6 2000	Volts 250 250 250 250 250 250 250	DC max Res. I 5 0.25 10 10 5 0.25 10	value Ind. 0.5 0.1 0.5 0.5 0.1 0.5	50 3.6 50 50 50 3.6 50
				Numb As req Code D4 P4 X4 H4 D8 P8	Type of switch 4 contact General Low pow Hermetic 8 cont General Low pow Hermetic	switch mechanism mechanism duty ct: 2 x SPST purpose ver circuits wer circuits cally sealed tact: DPDT purpose ver circuits	mism Max. wetside temp. 400°C 400°C 250°C 250°C 400°C 400°C	AC r Volts 440 250 440 440 250 440	max va Amps 5 0.25 10 10 5 0.25	enclosu lues VA 2000 6 2000 2000 6 2000 6 2000	Volts 250 250 250 250 250 250 250	DC max Res. I 5 0.25 10 10 5 0.25	value Ind. 0.5 0.1 0.5 0.5 0.5 0.1	50 3.6 50 50 50 3.6
				Numbi As req Code D4 P4 X4 H4 D8 P8 X8	Type of Switch 4 contact General Low pow Hermetic 8 cont General Low pow Hermetic Hermetic High pow Hermetic High pow Hermetic	switch mechanism mechanism duty ct: 2 x SPST purpose ver circuits wer circuits cally sealed tact: DPDT purpose ver circuits	mism Max. wetside temp. 400°C 400°C 250°C 250°C 400°C 250°C 250°C 250°C	AC r Volts 440 250 440 440 250 440	max va	enclosu lues VA 2000 6 2000 2000 6 2000 6 2000	Volts 250 250 250 250 250 250 250	DC max Res. I 5 0.25 10 10 5 0.25 10	value Ind. 0.5 0.1 0.5 0.5 0.1 0.5	50 3.6 50 50 50 3.6 50
				Numbi As req Code D4 P4 X4 H4 D8 P8 X8	Type of switch 4 contact General Low pow Hermetic General Low pow Hermetic General Code N 0	e max. number e mechanism duty ct: 2 x SPST purpose ver circuits cally sealed tact: DPDT purpose ver circuits ver circuits ver circuits cally sealed Mounting arran L" NPT thread	S Allowab	AC r Volts 440 250 440 440 250 440 440	5 0.25 10 10 5 0.25 10 10	enclosu lues VA 2000 6 2000 2000 6 2000 2000 standa	Volts 250 250 250 250 250 250 250 250	DC max Res. I 5 0.25 10 10 5 0.25 10	value Ind. 0.5 0.1 0.5 0.5 0.5 0.5 0.5	50 3.6 50 50 3.6 50 50
				Numbi As req Code D4 P4 X4 H4 D8 P8 X8	Type of switch 4 contact General Low pow Hermetic General Low pow Hermetic General Code N 0	switch mechanism mechanism duty ct: 2 x SPST purpose ver circuits cally sealed tact: DPDT purpose ver circuits cally sealed datact: DPDT purpose ver circuits ver circuits	S Allowab	AC r Volts 440 250 440 440 250 440 440	5 0.25 10 10 5 0.25 10 10	enclosu lues VA 2000 6 2000 2000 6 2000 2000 standa	Volts 250 250 250 250 250 250 250 250	DC max Res. I 5 0.25 10 10 These	value Ind. 0.5 0.1 0.5 0.5 0.5 0.1 are o	50 3.6 50 50 3.6 50 50
				Numbi As req Code D4 P4 X4 H4 D8 P8 X8	Type of switch 4 contact General Low pow Hermetic 8 cont General Low pow Hermetic Code 0 1 60 3 61	switch mechanism mechanism duty ct: 2 x SPST purpose ver circuits ver circuits cally sealed tact: DPDT purpose ver circuits ver circuits cally sealed tact: DPDT purpose ver circuits ver circuits ver circuits cally sealed Tourn on the sealed Mounting arrai Tourn of the sealed Tourn of t	S Allowab	AC r Volts 440 250 440 440 440 440 5.5 / B	max va Amps 5 0.25 10 10 5 0.25 10 10 S steel \$1560 \$1560	enclosu lues VA 2000 6 2000 2000 2000 2000 standar	Volts 250 250 250 250 250 250 250 250	DC max Res. I 5 0.25 10 10 These stocke	value Ind. 0.5 0.1 0.5 0.5 0.1 0.5 0.6 d flar	50 3.6 50 50 3.6 50 50
				Numbi As req Code D4 P4 X4 H4 D8 P8 X8	Type of switch 4 contact General Low pow Hermetic 8 cont General Low pow Hermetic Code N 0 1 60 3 61 3 62 3	ch mechanism e max. number switch mechan mechanism duty ct: 2 x SPST purpose ver circuits ver circuits cally sealed tact: DPDT purpose ver circuits	Max. wetside temp. 400°C 250°C 250°C 250°C 250°C 250°C 250°C NSI B16 NSI	AC r Volts 440 250 440 440 440 440 5.5 / B 5.5 / B	5 0.25 10 10 5 0.25 10 10 S steel \$1560 \$1	enclosu lues VA 2000 6 2000 2000 6 2000 standar	Volts 250 250 250 250 250 250 250 250	DC max Res. I 5 0.25 10 10 These stocke	value Ind. 0.5 0.1 0.5 0.5 0.5 0.5 def flange	50 3.6 50 50 50 50 50 50
				Numbi As req Code D4 P4 X4 H4 D8 P8 X8	Type of switch 4 contact General Low pow High pow Hermetic 8 cont General Low pow Hermetic 0 1 60 3 61 3 62 3 65 4	ch mechanism e max. number switch mechan mechanism duty ct: 2 x SPST purpose ver circuits ver circuits cally sealed tact: DPDT purpose ver circuits ver circuits cally sealed duty dunting arrai L" NPT thread B" # 150RF A B" # 300RF A B" # 300RF A B" # 150RF A	Max. wetside temp. 400°C 250°C 250°C 250°C 250°C 250°C NSI B16 N	AC r Volts 440 250 440 440 250 440 440 5.5 / B 5.5 / B 5.5 / B	5 0.25 10 10 5 steel \$1560 \$15	enclosu lues VA 2000 6 2000 2000 2000 standar	Volts 250 250 250 250 250 250 250 250	DC max Res. I 5 0.25 10 10 These stocke Other and ra availal	value Ind. 0.5 0.1 0.5 0.5 0.1 0.5 0.5 draged flangestings ble on	50 3.6 50 50 50 50 ur nges. e sizes are
				Numbi As req Code D4 P4 X4 H4 D8 P8 X8	Type of switch 4 contact General Low pow Hermetic 8 cont General Low pow Hermetic 0 1 60 3 61 3 62 3 65 4 66 4	switch mechanism mechanism duty ct: 2 x SPST purpose ver circuits ver circuits cally sealed tact: DPDT purpose ver circuits ver circuits cally sealed tact: DPDT purpose ver circuits	Max. wetside temp. 400°C 250°C 250°C 250°C 250°C 250°C NSI B16 N	AC r Volts 440 250 440 440 440 440 5.5 / B 5.5 / B 5.5 / B	5 0.25 10 10 5 steel \$1560 \$15	enclosu lues VA 2000 6 2000 2000 2000 2000 standal	Volts 250 250 250 250 250 250 250 250	DC max Res. I 5 0.25 10 10 These stocke Other and ra	value Ind. 0.5 0.1 0.5 0.5 0.1 0.5 0.5 draged flangestings ble on	50 3.6 50 50 50 50 ur nges. e sizes are
				Numbi As req Code D4 P4 X4 H4 D8 P8 X8	Type of switch 4 contact General Low pow Hermetic 8 cont General Low pow Hermetic 0 1 60 3 61 3 62 3 65 4 66 4	ch mechanism e max. number switch mechan mechanism duty ct: 2 x SPST purpose ver circuits ver circuits cally sealed tact: DPDT purpose ver circuits ver circuits cally sealed duty dunting arrai L" NPT thread B" # 150RF A B" # 300RF A B" # 300RF A B" # 150RF A	Max. wetside temp. 400°C 250°C 250°C 250°C 250°C 250°C NSI B16 N	AC r Volts 440 250 440 440 440 440 5.5 / B 5.5 / B 5.5 / B	5 0.25 10 10 5 steel \$1560 \$15	enclosu lues VA 2000 6 2000 2000 2000 2000 standal	Volts 250 250 250 250 250 250 250 250	DC max Res. I 5 0.25 10 10 These stocke Other and ra availal	value Ind. 0.5 0.1 0.5 0.5 0.1 0.5 0.5 draged flangestings ble on	50 3.6 50 50 50 50 ur nges. e sizes are
				Numbi As req Code D4 P4 X4 H4 D8 P8 X8	Type of switch 4 contact General Low pow Hermetic 8 cont General Low pow Hermetic 0 1 60 3 61 3 62 3 65 4 66 4	switch mechanism mechanism duty ct: 2 x SPST purpose ver circuits ver circuits cally sealed tact: DPDT purpose ver circuits ver circuits cally sealed tact: DPDT purpose ver circuits	Max. wetside temp. 400°C 250°C 250°C 250°C 250°C 250°C NSI B16 N	AC r Volts 440 250 440 440 440 440 5.5 / B 5.5 / B 5.5 / B	5 0.25 10 10 5 steel \$1560 \$15	enclosu lues VA 2000 6 2000 2000 2000 2000 standal	Volts 250 250 250 250 250 250 250 250	DC max Res. I 5 0.25 10 10 These stocke Other and ra availal	value Ind. 0.5 0.1 0.5 0.5 0.1 0.5 0.5 draged flangestings ble on	50 3.6 50 50 50 ur nges. e sizes are

Note: Instrument pressure rating is the lower of either the float or mounting flange


Direct Mounting Float Dimensions



Switch Enclosures



Switch Mechanisms



3.0 Carbon Steel Chamber Mounted Controls: Ordering Information

								manufac									
								per for ro	outine	mainten	ance						
Code	1	rial of on stee				amber	f										
	Code	_		Jage 1	. :												
	Couc	_	and tri	m M	linin	num	Procei	ura ratin	g (har)	. See no	tos					Ch	ambe
			aterial	"	S.C		20℃		s (bar) 250℃		0℃						ly size
	1F				8.0		34.5		22.0		0.0	R	efer to	page	15		N.B.
	2F] 3	316		0.7		102.3	I .	83.4	I	9.0		for pr				
	3F		inless		0.6		51.1	I .	41.7	I	1.5		conne				
	4F 7D	s	teel		0.5		19.6	I .	12.1	I	.5			ngs		٠.,	
	70	Cada	Switc	h Ena	0.4		102.3	<u> </u>	83.4	65	9.0	Note	: single	SWITC	n only	4"	N.B.
		Code	SWILC	n Enc	iosu	re	Mater	ial of		Materia	l of	Sw	itch	М	ax. no.	of swi	tches
				Duty		В	ase	Cove	er	wetted p			tment	1	ontact	1	Conta
		R4N		herpro	of		ninium	Draw					one	1	1		1
		S4N		P66			loy*	stee	1	316		100	Omm		4		2
		R7A					ninium	Alumin		stainle			one		1		1
		S7A	ı	nepro			loy*	allo		steel			Omm	1	4		2
		R71 S71	EEX	dIICT	0		Cast	Cas					one Omm		4		2
		3/1					ron	iror		ast iron w	honovi			witaha		a a sifi a	
			Code	Num	hor			chanism:		ast from w	meneve	er 6 COI	itact sv	vitche	s are sp	Jecine	u
			1 - 4						_	able in sv	witch e	nclosur	e and f	float c	lata abo	ove	
				Code				mechani									
					Ť		ch mecl			wetside	A.C.	max. va	alues		D.C. n	ıax. va	lues
							duty		tem	perature	Volts	Amps	VA	Volts	Res.	Ind. I	Wat
				D 4				× SPST] ,	0.000	440	_	0000	050	_	٥٦	
				D4 P4			purpose er circu			00°C	440 250	5 0.25	2000	250 250		0.5	50 3.6
				X4			ver circ			50°C	440	10	2000	250		0.1	50
				H4			cally sea			50℃	440	10	2000	250		0.5	50
							ontact:										
				D8			purpose			00℃	440	5	2000	250		0.5	50
				P8			er circu			00℃	250	0.25	6	250			3.6
				X8 H8			wer circ cally sea			50℃ 50℃	440 440	10 10	2000	250 250		0.5	50 50
				ПО		I	carry sea	aleu		50 C	440	10	2000	250	10	0.5	50
					/	Code	Droce	es conne	oction	configura	ation						
						1		bottom	CLIOII	Comiguia	211011						
						2		side with	1" N	PT dram							
							Code	Process	conn	ection siz	ze & ra	ting	Chamb	er			
							01			16 s/s sta							
							11	1" # 1									
l l							12	1" # 3				3"	' & 4"	N.B.		These	
							13 15	1" # 60 DN25 I		•						stocke	ed SIZE
							16	DN25 I								Other	flans
							17	DN25 I							size	es and	
							18	DN25 I	PN64							are av	
							19	DN25 F								on i	eque
								11/2" #	150 F	₹.F.							
							21	1½"#		\ _						nent n	ressu
							22	1½"#	300 F						Instrun		بدرها م
							22 23	1½" # 1½" #	300 F 600 F						ratin	g is th	
							22	1½"#	300 F 600 F PN16	R.F.		4	" N.B.		ratin of ei	g is th ther th	ne flo
							22 23 25	1½" # 1½" # DN40 F	300 F 600 F PN16 50 R.F	R.F. - .		4	" N.B.		ratin of ei	g is th	ne flo
							22 23 25 31 32 33	1½" # 1½" # DN40 I 2" # 1 2" # 3 2" # 6	300 F 600 F N16 50 R.F 00 R.F	₹.F. - .		4	" N.B.		ratin of ei	g is th ther th	ne flo
							22 23 25 31 32 33 35	1½" # 1½" # DN40 I 2" # 1! 2" # 30 2" # 60 DN50 I	300 F 600 F N16 50 R.F 00 R.F O0 R.F	₹.F. - .		4'	" N.B.		ratin of ei	g is th ther th	ne flo
							22 23 25 31 32 33 35 36	1½" # 1½" # DN40 I 2" # 1! 2" # 3! 2" # 6! DN50 I DN50 I	300 F 600 F N16 50 R.F 00 R.F N16 PN25	₹.F. - .		41	" N.B.		ratin of ei	g is th ther th	ne flo
							22 23 25 31 32 33 35	1½" # 1½" # DN40 I 2" # 1! 2" # 30 2" # 60 DN50 I	300 F 600 F N16 50 R.F 00 R.F N16 PN25	₹.F. - .		4'	" N.B.		ratin of ei	g is th ther th	ne flo


Note: State process connection centres when ordering. See page 14 for standard dimensions. Instrument pressure rating is the lower of either the float or the process flange.


Chamber Type and Material of Construction

Carbon steel: Bottle construction BS

Carbon steel: Flanged construction

XS






Float is sealed inside chamber during manufacture.


Float may be removed from chamber for routine maintenance, cleaning or inspection.

Switch Enclosures

Weatherproof: R4N S4N

Flameproof: R7A S7A R71 S71






Switch Mechanisms

4 contact: D4 P4 X4 H4

8 contact: D8 P8 X8 H8






 $2 \times \text{independent SPST}$ AA make on rise: BB make on fall

Double pole double throw (4 \times independent SPST) AA make on rise: BB make on fall

Process Connection Configuration



Chamber dimensions, operating levels and technical data are given on page 14

4.0 316L Stainless Steel Chamber Mounted Controls: Ordering Information

								during			mainten	2000						
(Code		rial of o						Jei IOI II	Juline	mamien	ance						
	S	1	stainle					•										
		Code	Floats	s														
				and tri aterial	m N	/linin S.C		Pressu 20°C		g (bar) 250℃	See no	tes 0°C						amber ly size
		0.5					_						R	efer to		15		
		2F 3F		316		0.7		82.7		57.4		5.3		for pr			4"	N.B.
		4F		iinless steel		0.6 0.5		41.4 15.9		26.7 10.2		3.2		conne rati			4	IN.D.
		7D		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		0.4		82.7		57.4		5.3	Note	: single		h only		
			Code	Switc	h Enc	losu	re				<u>'</u>							
				١.			_	Mater	I		Materia			itch		ax. no.	1	
			R4N		Duty herpr	oof		Base minium	Cove Drav		wetted p	oarts		stment one	4 Co	ontact 1	80	Contact
			S4N		nerpr P66	001	l .	lloy*	stee		316			Omm		4		2
			R7A					ninium	Alumir		stainle			one		1		1
			S7A		nepro			lloy*	allo		stee	l		Omm		4		2
			R71	EEx	dIICT	6	l .	Cast	Cas					one		1		1
			S71					iron	iror		.4.1	d		Omm		4		2
				Code	N	ahar		Base mat			st iron w	neneve	er & cor	ntact sv	vitches	are sp	ecifie	ב
				1 - 4							ble in s	witch e	nclosur	re and t	float d	ata aho	DVE	
					Cod			f switch			1010 111 31	WILCH C	Ticiosai	C dild i	TOUL G	ata abt	-	
							<u> </u>	ch mech			wetside	A.C.	max. v	alues		D.C. m	ax. va	lues
								duty		temp	erature	Volts	Amps	VA	Volts	Res. I	Ind. I	Watts
					D4			ntact: 2			2000	440	_	2000	٥٥٥	_	٦	
					D4 P4			purpose ver circu			00℃ 00℃	440 250	5 0.25	2000	250 250	5 0.25	0.5	3.6
					X4			wer circ			50°C	440	10	2000	250	10	0.5	50
					Н4			cally sea			50°C	440	10	2000	250	10	0.5	50
								ontact:		_			_			_		
					D8 P8			purpose			00℃ 00℃	440 250	5 0.25	2000	250 250	5 0.25	0.5	50 3.6
					X8			ver circu wer circ			50°C	440	10.25	2000	250	10	0.1	50
					H8			cally sea			50℃	440	10	2000	250	10	0.5	50
						1				1								
						Т	Code	Proce	ss conn	ection	configura	ation						
							1		oottom	1 22 8.22								
							2		side with			0	4 !					
								Code 01			stainles			ard				
								11			. ANSI E							
								12			ANSIE							
								13			ANSIE							
								21 22			.F. ANS .F. ANS							
								23			.F. ANS							
								31			ANSLE							
								32			ANSIE							
								33	2" # 6	00 R.F	ANSIE	316.5/1	BS1560)				
						,	,	,										
,	14	N/		W/	*/	v	v	v										
V B	S	V 7D	4N	1	X8		2	33						Tve	nical a	rdering	r infor	mation


Note: State process connection centres when ordering. See page 14 for standard dimensions. Instrument pressure rating is the lower of either the float or the process flange.


Chamber Type and Material of Construction

Carbon steel: Bottle construction BC

Carbon steel: Flanged construction

XC






Float is sealed inside chamber during manufacture.


Float may be removed from chamber for routine maintenance, cleaning or inspection.

Switch Enclosures

Weatherproof: R4N S4N

Flameproof: R7A S7A R71 S71






Switch Mechanisms

4 contact: D4 P4 X4 H4

8 contact: D8 P8 X8 H8







 $2 \times \text{independent SPST}$ AA make on rise: BB make on fall

Double pole double throw (4 \times independent SPST) AA make on rise: BB make on fall

Process Connection Configuration



Chamber dimensions, operating levels and technical data are given on page 14



Notes: C = Highest operating liquid level

D (Single switch) = Reset level

D (Multi switch) = Lowest operating liquid level

D-C = Wet switching differential (max)

All dimensions in mm.

NOTE: Dimensions given are for reference only, and must be certified on order.

Dimensional data: enclosures					
Туре	Duty	Height G	Conduit thread*	Switch adjustment	Weatherproof rating
R7A, R71	Flameproof	190	1" NPT	None	IP66 to IEC 144
S7A, S71	EExdIICT6	300		100	(NEMA 4)
R4N		170		None	IP66 to IEC 144
S4N	Weatherproof	275	1" NPT	100	(NEMA 4)
L4N		375		200	

^{*}Enclosures for use with 8 contact switch mechanisms have both conduit entries threaded, whilst those for use with 4 contact switch mechanisms have only one conduit entry.

Technical Data

Mobrey vertical level controls are manufactured to the highest standards of quality with only certified materials: BS EN 10204 3.1B. Design of Mobrey chambers is in accordance with ANSI B31.3.

Welding is qualified to ASME IX, BS4870 and BS4871. Circumferential and set-on branch welds are full penetration welds, with visual inspection in accordance with ANSI B31.3 "normal service" requirements and our company standard 417.


All pressure retaining assemblies are hydrostatically pressure tested to a minimum of $1.25 \times$ maximum working pressure or to flange standard requirements.

Radiography or other NDT techniques can be accommodated provided that they are specific at time of order entry.

Inspection

Whilst Mobrey employ inspectors in house, unconnected with production, customers frequently ask for outside inspection. We are happy to accommodate nominated inspectors if agreed at order entry.

Some specifications require a quality control plan detailing inspection points and hold points. Mobrey will produce these QC plans for customer approval if agreed at order entry.



Pressure Ratings (bar)

Material	Ca	arbon steel: A10	5	S	tainless steel: 31	6L
	20℃	250℃	400℃	20℃	250℃	400℃
ANSI # 150	19.6	12.1	6.5	15.9	10.2	6.5
ANSI # 300	51.1	41.7	34.5	41.4	26.7	23.2
ANSI # 600	102.1	83.4	69.0	82.7	57.4	46.3
BS4504 PN16	16	14.4	8.8	15.2	9.9	8.4
BS4504 PN25	25	22.5	13.8	23.8	15.5	13.2
BS4504 PN40	40	36	22	38	24.8	21.1

Materials of construction	Carbon steel chamber	Stainless steel chamber
Chamber tube	ASTM A106 Gr B / BS3602 HFS410	ASTM A312 T316L / BS3605-316-S14
Top casting	ASTM A216 / BS1504-161-430A	
Top/bottom caps	ASTM A105 / BS1503-221-430E	ASTM A182 F316L / BS1503-316-S13
Top cover	ASTM A105 / BS1503-221-430E	ASTM A182 F316L / BS1503-316-S13
Flanges/fittings	ASTM A105 / BS1503-221-430E	ASTM A182 F316L / BS1503-316-S13
Studs	ASTM A193-B7 / BS1506-621A-B7	ASTM A193-B7 / BS1506-621A-B7
Nuts	ASTM A194-2H / BS1506-162-2H	ASTM A192-2H / BS1506-162-2H

Options

- Low temperature carbon steel
- Cr. mo. steels
- Duplex UNS31803
- Ratings up to ANSI #2500
- N.A.C.E. requirements
- N.D.T. to your specifications
- 3.1b Identifiable certification
- Vent and drain connections

Process connections to specification